



Center City PCS [Congress Heights] - Lead in Water Test Results



FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier(High/Low)	Location Identifier(Left/Mid/Right)	Water Filter ID	Date Analyzed	FT Sample ID - 1st Draw	FT Result 1st Draw(ug/L)	FT Sample ID - 2nd Draw	FT Result 2nd Draw(ug/L)
Center City PCS [Congress Heights]	WS-123-001	Food Prep Sink	Basement	In kitchen			WF-032021-123001-03	6/7/2021	FT-FY21-032021-123001-A	<1	FT-FY21-032021-123001-B	<1
Center City PCS [Congress Heights]	WS-123-002	Cooler	2	In hallway adjacent to teachers lounge			WF-032021-123002-03	N/A	FT-FY21-032021-123002-A	Non-Op	FT-FY21-032021-123002-B	Non-Op
Center City PCS [Congress Heights]	WS-123-003	Cooler	3	In hallway adjacent to classroom 302			WF-032021-123003-03	N/A	FT-FY21-032021-123003-A	Non-Op	FT-FY21-032021-123003-B	Non-Op
Center City PCS [Congress Heights]	WS-123-004	Bottle Filler	2	In hallway adjacent to teachers lounge			WF-032021-123004-01	6/7/2021	FT-FY21-032021-123004-A	<1	FT-FY21-032021-123004-B	<1
Center City PCS [Congress Heights]	WS-123-005	Bottle Filler	3	In hallway adjacent to classroom 302			WF-032021-123005-01	6/7/2021	FT-FY21-032021-123005-A	<1	FT-FY21-032021-123005-B	<1