



Center City PCS [Brightwood] - Lead in Water Test Results



FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Center City PCS [Brightwood]	WS-023-001	Cooler	1	In hallway across from main office	High	Left	WF-022021-023001-03	N/A	FT-FY21-022021-023001-A	Non-Op	FT-FY21-022021-023001-B	Non-Op
Center City PCS [Brightwood]	WS-023-002	Cooler	1	In hallway across from main office	Low	Right	WF-022021-023002-03	N/A	FT-FY21-022021-023002-A	Non-Op	FT-FY21-022021-023002-B	Non-Op
Center City PCS [Brightwood]	WS-023-003	Health Suite	2	In health suite		Left	WF-022021-023003-03	6/16/2021	FT-FY21-022021-023003-A	<1	FT-FY21-022021-023003-B	<1
Center City PCS [Brightwood]	WS-023-009	Cooler	4	In hallway adjacent to room 401			WF-022021-023009-03	N/A	FT-FY21-022021-023009-A	Non-Op	FT-FY21-022021-023009-B	Non-Op
Center City PCS [Brightwood]	WS-023-010	Bottle Filler	1	In hallway across across from main office			WF-022021-023010-01	6/16/2021	FT-FY21-022021-023010-A	<1	FT-FY21-022021-023010-B	<1
Center City PCS [Brightwood]	WS-023-011	Bottle Filler	4	In hallway adjacent to room 401			WF-022021-023011-01	6/16/2021	FT-FY21-022021-023011-A	<1	FT-FY21-022021-023011-B	<1

Greater than 5 ppb - Devices Requiring Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Center City PCS [Brightwood]	WS-023-006	Food Prep Sink	2	In kitchen 2nd clockwise from door		Right	WF-022021-023006-03	6/16/2021	FT-FY21-022021-023006-A	<1	FT-FY21-022021-023006-B	6.2

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Center City PCS [Brightwood]	WS-023-006	Food Prep Sink	2	In kitchen 2nd clockwise from door		Right	WF-062021-023006-04	6/24/2021	FT-FY21-022021-023006-A	<1	FT-FY21-022021-023006-B	<1